



## REPORT FOR RIMA INTERNATIONAL VERIFICATION PROGRAM FOR NORTH AMERICA

This verification has been prepared in accordance with the *Voluntary Product Verification Program* administered by the Reflective Insulation Manufacturers Association International. The tests reports and supporting documentation were submitted to RIMA-I for transmittal to R&D Services, Inc. for review.

Manufacturer: RoyOMartin

Date of Application: 12/14/09

Location: Alexandria, LA

Date of Review: 1/1/2010

Product Name: Eclipse Radiant Barrier Panel (OSB) Category: Radiant Barrier (2)

<u>Required ASTM Test Reports</u>	<u>Date</u>	<u>Content</u>	<u>Laboratory</u>
C 1371 (emittance)	7/31/09	OK	OK
E 84 (flame spread)	4/30/09	OK	OK
E 84 (smoke developed)	4/30/09	OK	OK
E 96 (water vapor transmission)	10/12/09	OK	OK
D 3310 (corrosion)	10/12/09	OK	OK
D 2261 (tear resistance)	7/24/09	OK	OK
C 1338 (fungi resistance)	9/28/09	OK	OK
C 1313/10.1 (bleeding and delamination)	7/31/09	OK	OK
C 1313/10.2 (pliability)	7/31/09	OK	OK

Technical Data Sheets: Cites emittance 0.03, test value 0.04. E 84 data for one Product thickness – data sheet identifies multiple thicknesses. Data sheet includes plywood. Data submitted are for Eclipse on OSB.

Websites: [www.RoyOMartin.com](http://www.RoyOMartin.com)

The product satisfies the radiant barrier requirements of the RIMA-I verification program.

A handwritten signature in black ink that reads 'David W. Yarbrough'.

David W. Yarbrough, PhD, PE