



## REPORT FOR RIMA INTERNATIONAL VERIFICATION PROGRAM FOR NORTH AMERICA

This verification has been prepared in accordance with the *Voluntary Product Verification Program* administered by the Reflective Insulation Manufacturers Association International. The test reports and supporting documentation were submitted to RIMA-I for transmittal to R&D Services, Inc. for review.

Manufacturer: RoyOMartin  
Location: Alexandria, LA  
Product Name: Eclipse

Date of Application: August 11, 2017  
Date of Review: October 7, 2017  
Product Category: 1

### Weather Resistance Barrier

<u>Required ASTM Test Reports</u>	<u>Date</u>	<u>Content</u>	<u>Laboratory</u>
C 1371 (emittance)	8/15/17	satisfactory	satisfactory
E 84/E 2599 (flame spread)	6/5/17	satisfactory	satisfactory
E 84/E 2599 (smoke developed)	6/5/17	satisfactory	satisfactory
E 96 (water vapor transmission)-retarder	8/15/17	satisfactory	satisfactory
C 1258 (temp-humidity resistance)	8/15/17	satisfactory	satisfactory
C 1224/9.5.1 (bleeding and delamination)	8/15/17	satisfactory	satisfactory
C 1224/9.5.2 (pliability)	8/15/17	satisfactory	satisfactory
C 1338 (fungi resistance)	8/15/17	satisfactory	satisfactory
C 1224/6.7 (thermal resistance)	None listed		
D 882 (2000 h, UV G154, cycle 1)	Not applicable		

Technical Data Sheets: Eclipse-Weather Resistant Barrier

Basis for thermal resistance (R-value) claim: No R-value claimed

Websites: [www.royomartin.com](http://www.royomartin.com)

The product **satisfies** the reflective insulation requirements of the RIMA-I verification program.

A handwritten signature in cursive script that reads 'David W. Yarbrough'.

David W. Yarbrough, PhD, PE