

## REPORT FOR RIMA INTERNATIONAL VERIFICATION PROGRAM FOR NORTH AMERICA

This verification has been prepared in accordance with the *Voluntary Product Verification Program* administered by the Reflective Insulation Manufacturers Association International. The tests reports and supporting documentation were submitted to RIMA-I for transmittal to R&D Services, Inc. for review.

Manufacturer: RoyOMartin Date of Application: 12/14/2009 Location: Alexandria, LA Date of Review: 1/1/2010 Product: Eclipse Energy Guard (OSB) Product Category: (1) Reflective Insulation

Required ASTM Test Reports	Date	Content	Laboratory
C 1371 (emittance)	7/31/09	OK	OK
E 84/E 2599 (flame spread)	4/30/08	OK	OK
E 84/E 2599 (smoke developed)	4/30/08	OK	OK
E 96 (water vapor transmission)	n/a		
C 1258 (temp-humidity resistance))	10/12/09	OK	OK
C 1224/9.5.1 (bleeding and delamination)	7/31/09	OK	OK
C 1224/9.5.2 (pliability)	7/31/09	OK	OK
C 1338 (fungi resistance)	9/28.09	OK	OK

Technical Data Sheets: Reviewed. E 84 completed for one thickness. Data sheet shows multiple thicknesses.

Websites: www.RoyOMartin.com

The product satisfies the reflective insulation requirements of the RIMA-I verification program.

David W. Yarbrough, PhD, PE